



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Certificate of constancy of performance 0843-CPR-0312

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

TBT FIRESTOP 50

Linear Joint Seal and Penetration Seal Classified for use in flexible & solid walls and solid floors

A sealant used to seal around cables and metallic and plastic pipes to form a penetration seal to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. The sealant may also be used to seal linear gaps and joints in and between wall and floor constructions to reinstate the fire resistance performance of wall and floor constructions, where they abut or include gaps. TBT FIRESTOP 50 is supplied in liquid form contained within 310 ml cartridges. The sealant is gunned into the aperture in or between the separating element/elements and where appropriate around the service or services, to a specified depth utilising various backing materials.

placed on the market by

Täby Brandskyddsteknik AB
Vasavägen 21
187 73 TÄBY,
SWEDEN

and produced in the factory

A/003

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the ETAs:

ETA 16/0323 & ETA 16/0324

under system AVCP 1 for the performance set out in this certificate are applied and that

TBT FIRESTOP 50 fulfils all the prescribed requirements for these performances.

This certificate was first issued on 29th June 2016 and will remain valid as long as the ETA remains valid and the manufacturing conditions in the plant or the factory production control itself are not modified significantly, unless suspended or withdrawn by the product certification body.

First issue date: 29th June 2016

Signature:

Chris Miles
for
UL International (UK) Ltd.



EC CERTIFICATE

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0312

Product/Device description:

TBT FIRESTOP 50

Applicant designation:

Täby Brandskyddsteknik AB
Vasavägen 21
187 73 TÄBY
SWEDEN

Product Information:

TBT FIRESTOP 50

The referenced product complies with:

A – All the relevant requirements as per ETA 16/0323 & ETA 16/0324 issued 29th June 2016

A handwritten signature in purple ink, appearing to read 'Chris Miles'.

Chris Miles
for
UL International (UK) Ltd.